

Marysville District

2006 Water Quality Report



Your Water Quality Report

At California Water Service Company (Cal Water), we are committed to supplying you with high-quality water. We are pleased to provide this annual water quality report, which includes information about where your water comes from, what it contains, and how it compares to state and federal standards. It also explains the steps we take to protect your water supply.

We care about what you think. If you have any suggestions or concerns, please call us. Also, please watch for bill inserts, where you will find announcements of any water-related public meetings or workshops, as well as important information about your water.

Inside the Water Quality Lab

At Cal Water's multi-million-dollar, state-of-the-art laboratory in San Jose, California, it's the little things that count. Cal Water's chemists and microbiologists conduct more than 300,000 separate water quality tests every year, looking for organic and inorganic compounds in the water in quantities as small as parts per trillion — that's like looking for bad pennies in three football stadiums filled with coins.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our scientists examine water samples that are carefully shipped to the lab from sampling stations throughout Cal Water's systems to ensure that your water meets or surpasses strict state and federal water quality standards.

Because protecting our customers' health and safety is our highest priority, Cal Water staffs its lab with some of the best scientists in the water industry. The entire laboratory operation is fully certified by the California Environmental Laboratory Accreditation Program — one of the toughest certifications to achieve in the country.

You might not have thought much about Cal Water's water quality laboratory, but the scientists in the lab have thought about your water. Every drop of it.



How to Read This Table

We test your water for more than 100 regulated contaminants. **The table in this report lists only those that were detected.**

The table shows water quality test results divided into two main sections: “primary standards” and “secondary standards.” Primary standards protect public health by limiting the levels of contaminants in drinking water. Secondary standards are limits for substances that could affect the water’s taste, odor, or appearance.

Where Your Water Comes From

Cal Water has provided high-quality water utility services in Marysville since 1930. To meet the needs of our customers, we utilize 12 wells to pump up to six million gallons of groundwater per day, which are delivered through 55 miles of pipeline, two storage tanks, and three booster pumps. We continue to monitor all active wells for MTBE. MTBE was not detected in any active wells in 2006. Our vigilant monitoring and proactive capital improvement programs help ensure a continued reliable supply of high-quality water.

In 2006, we added our second manganese removal plant to improve water quality for our customers. We also completed a 500,000 gallon storage tank (with two booster pumps) to improve our ability to meet peak water demand periods and to enhance fire-fighting capability. Additionally, we installed chlorine analyzers at four of our wells, which allows us to monitor our distribution system’s bacteriological protection on a real-time basis through our computerized SCADA control system. Finally, we replaced approximately 800 feet of undersized and deteriorating distribution system mains, which improved circulation for water quality, pressure, and fire-protection supply.

Drinking Water Source Assessment and Protection Program (DWSAPP)

By the end of 2002, Cal Water had submitted to the California Department of Health Services a DWSAPP report for each water source in the water system. The DWSAPP report identifies possible sources of contamination to aid in prioritizing cleanup and pollution prevention efforts. All reports are available for viewing or copying at our Customer Center.

The water sources in your district are considered most vulnerable to existing and historic gas stations, injection wells, known contaminant plumes, underground storage tanks, chemical/petroleum industries, dry cleaners, metal plating/fabrication, wastewater, and landfills/dumps.

A copy of this assessment may be viewed at:
DHS Valley District Office
415 Knollcrest Drive, Suite 110
Redding, CA 96002

We encourage customers to join us in our efforts to prevent water pollution and protect our most precious natural resource.

Water Hardness

Water is considered soft if total hardness is less than 75 ppm, moderately hard at 75 to 150 ppm, hard at 150 to 300 ppm, and very hard at 300 ppm or higher. To convert the hardness of your water from parts per million to grains per gallon, simply divide by 17.1.

Water’s hardness varies with its source. Hard water is not harmful to health, so the choice to buy a water softener is an aesthetic one. However, people on low-sodium diets should be aware that many water softeners increase the sodium content of the water.

2006 Water Quality Report

PRIMARY DRINKING WATER STANDARDS								
RADIOLOGICAL	Year Tested	Unit	MCL	PHG (MCLG)	Violation	Range	Average	Source of Substance
Gross Alpha Particle Activity	2003–2006	pCi/l	15	(0)	No	ND–7.75	1.1	Erosion of natural deposits
Uranium	2003–2006	pCi/l	20	0.5	No	ND–5.6	1.9	Erosion of natural deposits
INORGANIC CHEMICALS	Year Tested	Unit	MCL	PHG (MCLG)	Violation	Range	Average	Source of Substance
Arsenic ¹	2004–2006	ppb	10	0.004	No	3.5–9.6	6.9	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Chromium	2004–2006	ppb	50	(100)	No	ND–5.8	2.4	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Nitrate (as nitrate)	2006	ppm	45	45	No	ND–10	5.4	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
DISINFECTION BY-PRODUCTS	Year Tested	Unit	MCL	PHG (MCLG)	Violation	Result		Source of Substance
TTHMs (total trihalomethanes)	2006	ppb	80	n/a	No	9.5		By-product of drinking water chlorination
Total Haloacetic Acids (HAA5)	2006	ppb	60	n/a	No	1.9		By-product of drinking water chlorination
DISINFECTANT	Year Tested	Unit	MRDL	MRDLG	Violation	Range	Average	Source of Substance
Chlorine	2006	ppm	4	4	No	0.2–1.2	0.4	Drinking water disinfectant added for treatment
MICROBIOLOGICAL	Year Tested	Unit	MCL	(MCLG)	Violation	Highest Monthly		Source of Substance
Total Coliform (systems with <40 samples/month)	2006	positive samples	1	(0)	No	0		Naturally present in the environment

OTHER REGULATED SUBSTANCES								
METALS	Year Tested	Unit	AL	PHG	Violation	90th Percentile	# of Samples Exceeding AL	Source of Substance
Copper	2004	ppm	1.3	0.17	No	0.52	0 of 31	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

SECONDARY DRINKING WATER STANDARDS AND UNREGULATED COMPOUNDS								
INORGANIC CHEMICALS	Year Tested	Unit	SMCL	PHG (MCLG)	Violation	Range	Average	Source of Substance
Calcium	2004–2006	ppm	n/a	n/a	No	34–53	42	Erosion of natural deposits
Chloride	2004–2006	ppm	500	n/a	No	3.3–19	9.1	Erosion of natural deposits; seawater influence
Chromium 6+	2004–2006	ppb	n/a	n/a	No	1–2	1.3	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Color	2004–2006	Units	15	n/a	No	1–4	1.9	Naturally occurring organic matter
Magnesium	2004–2006	ppm	n/a	n/a	No	21–34	30	Erosion of natural deposits
Manganese ²	2004–2006	ppb	50	n/a	Yes	ND–86	3.5	Leaching from natural deposits
pH	2004–2006	Units	n/a	n/a	No	7.4–7.9	7.6	Inherent characteristic of water
Sodium	2004–2006	ppm	n/a	n/a	No	9–23	15	Erosion of natural deposits; seawater influence
Specific Conductance	2004–2006	µS/cm	1600	n/a	No	352–575	465	Erosion of natural deposits; seawater influence
Sulfate	2004–2006	ppm	500	n/a	No	10–35	23	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids	2004–2006	ppm	1000	n/a	No	204–318	272	Runoff/leaching from natural deposits
Total Hardness	2004–2006	ppm	n/a	n/a	No	180–282	224	Erosion of natural deposits
Turbidity (groundwater)	2004–2006	NTU	5	n/a	No	0.05–0.15	0.1	Soil runoff
Vanadium	2004–2006	ppb	NL=50	n/a	No	10–13	12	Erosion of natural deposits, manufacturing of alloys and steel

Notes

1 While your drinking water meets the current standard for arsenic, it does contain low levels of arsenic. The standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. The California Department of Health Services continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

2 Manganese was detected above the Secondary MCL. Over the last 3 years we have installed treatment at two wells to remove Manganese.

Definitions

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as are economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap.

Notification Level (NL): A health-based advisory level for an unregulated contaminant in drinking water. It is used by DHS to provide guidance to drinking water systems.

µS/cm = measure of specific conductance
 n/a = not applicable
 ND = none detected
 NTU = nephelometric turbidity unit
 pCi/L = picoCuries per liter (measure of radioactivity)
 ppb = parts per billion (micrograms per liter)
 ppm = parts per million (milligrams per liter)
 SMCL = secondary maximum contaminant level

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health, along with their monitoring, reporting, and water treatment requirements.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Potential Sources of Contamination

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

The sources of drinking water (both tap and bottled) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water, which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people, such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, those with HIV/AIDS or other immune system disorders, some elderly people, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

Questions? Answers!

Is bottled water safer than tap water?

Tap water and bottled water both must meet strict water quality standards, but tap water is subject to more frequent testing and higher reporting standards. Bottled water is generally not better quality than what comes out of your tap, but it can cost \$2 or more per gallon. An average Cal Water customer could get 1,000 gallons of tap water for that same \$2.

Why do Cal Water employees occasionally open fire hydrants?

This is a process known as “flushing.” It is done periodically to remove sediment or sand from the water lines and ensure that water circulates adequately throughout the system. Fire hydrants may also be opened to conduct fire-flow capability tests.

How does dirt or sand get in my water?

Dirt or sand can occur naturally in groundwater or as a result of a water line repair. Flushing reduces the instances of dirt and sand in the water.

What causes an odor in my hot water?

If you detect an odor in your hot water that is not present in your cold water, you may need to adjust, flush, or repair your water heater. Check with the manufacturer for details. If you detect an odor in both the hot and cold water, inform your local Customer Center.

Why does my water have a milky or cloudy appearance?

This is usually caused by air bubbles in the water, which pose no health risk. If the water is allowed to sit, the air will dissipate and the water will clear. If it does not, inform your local Customer Center.



629 Ninth Street
Marysville, CA 95901-5253
(530) 742-6911
www.calwater.com

Should I buy a home filtration unit?

According to the United States Environmental Protection Agency, home treatment units are rarely necessary for health reasons — they are most often used to improve the aesthetic qualities of the water. If you choose to install a home treatment unit, be sure to follow the manufacturer’s maintenance instructions. Improperly maintained units can actually cause water quality problems. For example, carbon filters can grow bacteria if they are not changed as recommended.

Why does the taste of my water change throughout the year?

In some of our service areas, water sources change at certain times of the year due to the availability of supplies. Surface water, or water that comes from sources like rivers and lakes, tends to taste slightly different than water pumped from underground aquifers. Water from all sources must meet the same rigorous standards.

What causes color in the water?

Colored water is usually caused by naturally occurring organics and metals such as manganese. These typically do not pose a health hazard, but you should report any instances of colored water to your local Customer Center.

If you have any questions, please contact Lee Seidel, District Manager, at (530) 742-6911.

What About Fluoride?

Fluoride occurs naturally in many water sources, but Cal Water does not add fluoride to your water supply.

California law requires Cal Water to add fluoride as funding from federal grants or other sources becomes available. In the meantime, you might wish to check with your dentist to see if fluoride supplements are recommended for any children in your family. Note that supplements may not be recommended for children who attend a school that has fluoridated water.

Want to know more? For general information on water fluoridation, visit us online at www.calwater.com.