LEAD FREE REDUCED PRESSURE PRINCIPLE ASSEMBLIES (RP), APPROVED FOR USE BY THE STATE WATER RESOURCES CONTROL BOARD FOR USE ON POTABLE WATER SERVICE CONNECTIONS



Approval of backflow prevention assemblies used in potable water systems throughout California requires laboratory analysis and field verification by a third party testing facility (currently the University of Southern California Foundation for Cross Connection Control & Hydraulic Research (USC FCCC&HR). ANSI lab certification as lead free is also required. It is the responsibility of the customer to verify with the contractor, distributer or manufacturer that the backflow prevention assembly installed is the correct type, is approved by the USC FCC&HR, and is ANSI certified as lead free. The USC FCC&HR continually updates their approved list which can be downloaded at http://fccchr.usc.edu/list.html

READ AND UNDERSTAND ALL OF THE IMPORTANT INFORMATION PROVIDED WITH THIS LIST

			ONDERSTAND ALE OF THE IMIT ON TA				<u> </u>
Manufacturer	Model	Orientation	Sizes	Manufacturer	Model	Orientation	
Ames	Colt 400	Н	2 ½", 3", 4", 6", 8", 10"	Watts	LF909M1QT	Н	1 1/4", 1 1/2", 2"
	Colt 400BF	Н	4", 6"		LF909QT	H, V	3/4", 1"
	Colt 400N		2 ½", 3", 4", 6", 8"		LF919AQT		3/4", 1", 1 1/4", 1 1/2", 2"
	Colt 400Z	VUVD, VUVU	2 ½", 3", 4", 8"		LF919QT	H, VD	3/4", 1", 1 1/4", 1 1/2", 2"
	LF4000BM2	Н	1", 1 ¼", 1 ½", 2"		LFU919AQT	VUVD	³ ⁄ ₄ ", 1", 1 ¹ ⁄ ₄ ", 1 ¹ ⁄ ₂ ", 2"
	LF4000BM3	Н	3/4"		LFU919QT	H, VD	1", 1 ¼", 1 ½", 2"
	Maxim 400	Н	2 ½", 3", 4", 6", 8", 10"		SS009M3QT	Н	3/4"
	Maxim 400N	VUVD, VUVU	(6" VUVD Only) 2 1/2", 3", 4"		375, 375A	Н	2 ½", 3", 4", 6", 8", 10"
	Maxim 400Z	VUVD, VUVU	2 ½", 3", 6"		375AMS	Н	2 ½", 3", 4", 6", 8", 10"
	4000SS	Η	2 ½", 3", 4", 6"		375AR	Н	2 ½", 3", 4", 6", 8", 10"
Apollo Conbraco	RPLF4A	Н	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2", 3, 4, 6, 8, 10, 12		375AR1	Н	2 ½", 3", 4", 6", 8", 10"
	RPLF4AN	VUVD, VUVU	(¾", 1", 10", 12" VUVD Only) 2 ½", 3", 4", 6", 8"		375ARMS	Н	2 ½", 3", 4", 6", 8", 10"
	RPLF4AR	Н	2 ½", 3", 4", 6", 8", 10"		375ARXL	Н	2 ½", 3", 4", 6", 8", 10"
	RPLF40	Н	1 ¼", 1 ½", 2"		375AST	Н	2 ½", 3", 4", 6", 8", 10"
ARI	RP500	Н	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2"		375MS	Н	2 ½", 3", 4", 6", 8", 10"
	RP501	Н	³ ⁄ ₄ ", 1", 1 ¹ ⁄ ₄ ", 1 ¹ ⁄ ₂ ", 2"		375ASTR(MS)	Н	2 ½", 3", 4", 6", 8", 10"
Backflow Direct	Deringer 40,40G	Н	2 ½", 3", 4", 8"		375AXL	Н	2 ½", 3", 4", 6", 8", 10"
	Deringer 40X,40GX	Н	(4" 40GX Only), 6"		375ST	Н	3/4", 1"
	Magnum 40,40G	Н	2 ½", 3", 4", 8"		375XL	Н	3/4", 1", 1 1/2", 1 1/4" 2" 2 1/2", 3", 4", 6", 8", 10"
	Magnum 40X	Н	6"		375XLB	Н	3/4", 1", 1 1/4", 1 1/2", 2"
Febco	760	Н	2 ½", 3", 4", 6", 8", 10"		375XLMS	Н	2-½, 3", 4", 6", 8", 10"
	760N	VUVD	2 ½", 3", 4"		475, 475 MS	VUVD	(10" 475 Only) 2 ½", 3", 4", 6", 8"
	760Z	VUVU	2 ½", 3", 4"		475MS	Н	10"
	LF825Y	Н	³ ⁄4",1", 1 ½", 2"		475V	VUVU	2 ½", 3", 4", 6", 8", 10"
	LF825YA	H, HVD, VUH, VUVD	³ ⁄ ₄ ",1", 1 ¹ ⁄ ₂ ", 2"		475VMS	VUVU	2-½, 3", 4", 6", 8"
	LF860	H	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2", 2 ½", 3", 4", 6", 8", 10"		475VMS	Н	10"
	LF860U	Н	3/4", 1 1/4", 1 1/2", 2"		475V, 475VMS	VUVU	(10" 475V Only) 2-1/2, 3", 4", 6", 8"
	LF880V	VUVD, VUVU	2 ½", 3", 4", 6", 8", 10"		475VMS	Н	10"
	LF880W & WZ	VUVD, VUVU	4", 6", 8", 10"		475XL,475XLMS	VUVD	(10" Only 475XL) 2-½, 3", 4", 6", 8",
Watts	957	Η	2 ½", 3", 4", 6", 8", 10"		475XLMS	Н	10"
	957 BF		4", 6"		475XLV	VUVU	2-1/2, 3", 4", 6", 8",10"
	957N	VUVD, VUVU	(6" VUVD Only) 2 1/2", 3", 4", 8"		475XLVMS	VUVU	2-1/2, 3", 4", 6", 8"
	957NQT	VUVD, VUVU	2 ½", 3", 4"		475XLVMS	Н	10"
	957QT	Η	2 ½", 3", 4"		975XL2	Н	3/4", 1", 1 1/4", 1 1/2", 2"
	957Z	VUVD, VUVU	2 ½", 3", 4", 8"		975XL2BMS	Н	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2"
	957ZQT	VUVD, VUVU	2 ½", 3", 4"		975XL2MS	Н	3/4", 1", 1 1/4", 1 1/2", 2"
	967N	VUVD, VUVU	4", 6"		975XL2SE	VUVD, VUVU	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2"
	967Z	VUVD, VUVU	6"		975XL2SEU	VUVD, VUVU	³ ⁄4", 1", 1 ¹ ⁄4", 1 ¹ ⁄2", 2"
	994	Н	2 ½", 3", 4", 6"		975XL2TCU	Н	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2"
	LF009	Н	2 ½", 3"		975XL2U	Н	3/4", 1", 1 1/2", 2"
	LF009M2QT	Н	³ ⁄ ₄ ", 1",1 ¹ ⁄ ₄ ",1 ¹ ⁄ ₂ ", 2"		975XL2V	VUVD, VUVU	3⁄4", 1"
	LF009M2PCQT	Н	1", 2"		975XL3	Н	3/4", 1", 1 1/4", 1 1/2", 2"
	LF009M3PCQT	Н	3/4"		975XL3BFSS	Н	2"
	LF009M3QT	Н	3/11		975XL3SE	VUVD, VUVU	
	LF909	Н	2 ½", 3", 4", 6"		975XL3U	Н	³ ⁄ ₄ ", 1", 1 ½", 1 ½", 2"
	LF909M1	Н	8", 10"		975XLD	Н	3/4" RPDA Fire Bypass
	5501411		o , to		373ALD		**

Orientation: H=Horizontal, VD=Vertical Down, VUVU=Vertical Up Vertical Up, VU=Vertical Up, VUVD=Vertical Up Vertical Down VDVU=Vertical Down, HVD=Horizontal Vertical Down, VUH=Vertical Up Horizontal Vertical Up, VDVD=Vertical Up

Assemblies must be installed only in an orientation for which they are approved.

Refer to local building department for permit requirements. Installing a backflow prevention assembly creates a closed piping system. It is the customers responsibilty to have a qualified plumbing professional install thermal expansion protection to prevent personal injury or property damage. The specific size of backflow prevention assembly should be selected based on flow requirements. Pressure losses vary between sizes and manufacturers. Pressure losses at rated flow must be accounted for during system design. All installations must be in accordance with the California Plumbing Code and the requirements of California Water Service (Cal Water). The list provided by Cal Water is not an endorsement of any specific backflow prevention assembly. Cal Water has no financial interest in any of the companies listed.