

Los Altos Suburban

Calculation of Urban Water Supplier's Conservation Standard Supply Reliability for Three Additional Years of Drought			
Step 1: Determine Total Potable Water Demand (used in Step 3)			
Potable Water Production in Calendar Year 2013	4950.41		MG
Potable Water Production in Calendar Year 2014	4272.46		MG
Total Potable Water Demand	4611.44		MG
<i>= ([Potable Water Production 2013]+[Potable Water Production 2014])/2</i>			
Step 2: Calculate Total Potable Water Supply			
Potable Water Supply	Year 1	Year 2	Year 3
Local Surface Water (million gallons)	N/A	N/A	N/A
Imported Water (million gallons)	2411.3	2411.3	2411.3
Groundwater (million gallons)	5844	5844	5844
Total Potable Water Supply (million gallons)	8255.3	8255.3	8255.3
<i>= [Local Surface Water]+[Imported Water]+[Groundwater]</i>			
Step 3: Calculate Conservation Standard			
Total Potable Water Demand (from Step 1)	4611.435		MG
Total Potable Water Supply (from Step 2)	8255.3		MG
Supply Shortfall in Year 3 (negative amount indicates a surplus)	-3643.865		MG
<i>= [Total Potable Water Demand]-[Total Potable Water Supply]</i>			
Conservation Standard with Self-Certification of Supply Reliability			0%
<i>= [Shortfall in Year 3] / [Total Potable Water Demand]</i>			

Step 2 of Water Supply Reliability Certification and Data Submission Form

<< Enter name of urban water supplier

User Input Instructions

- (1) Please select units of measure from the dropdown menu.
- (2) Enter information on available water supplies and supplies committed to other uses.

LEGEND:

User Input or Selection	
Linked from User Input	

<< Select units of measure

Available Water Supplies

Sources of Supply	Name of Provider(s) or Description	Source used in prior years?	Water Available in			Wholesaler information Direct Web Link	Wholesaler Water System Number**
			WY 2017 *	WY 2018 *	WY 2019		
WHOLESALE SUPPLIED >> Provide direct web link(s) to information on the volume of water the wholesaler expects to deliver to the retailer water supplier in each year.							
Wholesaler 1	Santa Clara Valley Water District	Yes	2,411.3	2,411.3	2,411.3	http://www.valleywater.org/s	CA4310027
Wholesaler 2		Select Y/N					
Wholesaler 3		Select Y/N					
Wholesaler 4		Select Y/N					
Wholesaler 5		Select Y/N					
SELF-SUPPLIED							
Water Recycling (potable)		Select Y/N					
Surface water: SWP		Select Y/N					
Surface water: CVP		Select Y/N					
Surface water: Colorado River		Select Y/N					
Surface water: other (describe)		Select Y/N					
Surface water: other (describe)		Select Y/N					
Local Groundwater	Well Production	Yes	5,844.0	5,844.0	5,844.0		
Seawater Desalination		Select Y/N					
Transfers		Select Y/N					
Exchanges		Select Y/N					
Other (describe):		Select Y/N					
SUBTOTAL of available supplies (in units selected)			8,255.3	8,255.3	8,255.3		

<< Complete groundwater tab

<< To add more self-supplied sources, insert as many rows

* Any carryover from one year is incorporated in the supply of the following year, as legally allowed.

** Look up Water system number at this link: <https://sdwis.waterboards.ca.gov/PDWW/>

Rows can be inserted to account for other sources of supply (e.g., desalination of brackish water, banked water)

If a source has not been used in prior years, e.g., a new treatment facility will be constructed, supporting documentation must document when the new source will be fully implemented.

Water Supplies Committed to Other Uses (Not Available)

Other Uses	Describe	Quantity in WY 2017	Quantity in WY 2018	Quantity in WY 2019
Agriculture				
Commercial, industrial or institutional				
New residential customers				

Transfers				
Other:				
Other:				
SUBTOTAL of supplies not available (in units selected)		-	-	-

TOTAL available water supply (in units selected)	8,255.3	8,255.3	8,255.3
--	---------	---------	---------

(Subtotal of available supplies minus subtotal of supplies committed to other uses)

>>> Please enter values calculated below in Step 2 of the online form

TOTAL available water supply converted to acre feet	25,335	25,335	25,335
---	--------	--------	--------

>> If error, verify you have selected units of measure

California Water Service - Los Altos
Supporting Analysis and Calculations

Well ID	Design Flow (GPM)	Mgals
1	480	202
2	1000	420
3	850	357
4	450	189
5	350	147
6	1200	505
7	1200	505
8	1250	526
9	850	357
10	1050	442
11	900	378
12	1500	631
13	400	168
14	425	179
15	250	105
16	375	158
17	618	260
18	375	158
19	375	158
	Total	5844

Groundwater Supply Notes

We project that 5,844 million gallons (MG) will be available annually from groundwater sources in 2017, 2018, and 2019. This is a conservative figure based on 80% of the capacity of currently active wells run 24 hours a day, 7 days a week.

Information on Wholesaler

<http://www.valleywater.org/SWRCBposting/>